


## BOQ for Electrical works at VC Chamber, CU


Sl. No.	Item Description	Unit	Qty	Rate in Figure	Rate in Words	Amount (Rs.)
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required.					
	Group B	Point	12			
2	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required.					
	1 X 1.5 sq. mm + 1 X 1.5 sq. mm earth wire	Mtr.	45			
3	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.					
	5/6 A switch	Each	20			
	3 pin 5/6 A socket outlet	Each	5			
4	Supplying and fixing following size/ modules, GI box alongwith modular base & cover plate for modular switches in recess etc. as required.					
	6 Module (200mmX75mm)	Each	3			
	12 Module (200mmX150mm)	Each	1			
5	Supplying and fixing 5 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.					
	Single Pole	Each	6			
6	Supplying and fixing DP sheet steel enclosure on surface/ recess along with 25/32 A 240 V "C" curve DP MCB complete with connections, testing and commissioning etc. as required.	Each	1			
7	Laying and fixing of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size on wall surface as required..					
8	Upto 35 sq. mm (clamped with 1mm thick saddle)	Mtr	170			

**BOQ for Electrical works at VC Chamber, CU**

Sl. No.	Item Description	Unit	Qty	Rate in Figure	Rate in Words	Amount (Rs.)
9	Supply, fitting and fixing of recessed panel LED light as approved & directed by the deptt. Make- Philips (Model No- DN295B LED6S-6500 PSE WH S1)	Each	16			
10	Supply, fitting and fixing of recessed panel LED light as approved & directed by the deptt. Make- Philips Model No-Astra Spot 2-Watt LED COB	Each	15			
11	Supply, fitting and fixing of LED flood light as approved & directed by the deptt. Make- Philips Model No-BVP183 LED156 CW FG SYWB 150W PSU	Each	6			
12	Supply, fitting and fixing of LED spot light as approved & directed by the deptt. Make- Philips Model No-SM321P LED15S-5700 PSU NB DIA100 WH	Each	1			
13	Supply, delivery to site of following size 1.1kV XLPE UG armoured cable as as approved & directed by the department Make: Havells (As per the price list w.e.f 30.01.2023) 4 core, 16.0 sq. mm armoured cable	Mtr	170			
14	Supply, fitting and fixing of decorative ceiling fans as approved & directed by the deptt. Make- Crompton Model No- AURA	Each	4			
<b>Total in Rs.</b>						

•Rupees ..... Only





Sealed Signature of the Tenderer